

CERTIFICATE

of Conformity

Registration No.: AK 50702639 0001
Report No.: CN256KLD 002
Holder: VINH THINH ELECTRIC CABLE COMPANY
LIMITED
697 Provincial Road 2, Van Han Hamlet, Thai My Commune,
70000 Ho Chi Minh City,
Vietnam
Product: Cables / Wires
(Fire resistant cables of rated voltage 0,6/1kV)

Type designation and serial number are listed on the next page(s)

The certificate of conformity refers to the above-mentioned product. This is to certify that the specimen is in conformity with the assessment requirement mentioned on the next page. This certificate does not imply assessment of the production of the product and does not permit the use of a TÜV Rheinland mark of conformity.

Date: 2025-11-12

Certification Body


Kenny Shi



TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg

CERTIFICATE

of Conformity

Registration No.: AK 50702639 0001

Product: Cables / Wires
(Fire resistant cables of rated voltage 0,6/1kV)

Tested according to: BS 6387:2013

Identification: Type Designation
Cu/Mica/XLPE/FR-PVC 0,6/1kV 1x1,5...120mm²
Rating Voltage: 0,6/1kV

Serial No.:
Engineering Sample

Remark :
The cables comply with requirements of BS 6387:2013
Protocol C,W,Z.



TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg